

**ADDENDUM NO. 1**


**CITY OF HIALEAH  
DEPARTMENT OF PUBLIC WORKS  
3700 W 4 AVE  
HIALEAH, FLORIDA**

**February 10, 2015**

**TO ALL CONCERNED**

The original Contract Documents, for the Project entitled **CITY OF HIALEAH – PUBLIC WORKS COMPLEX-PARKING LOT-PAVING, DRAINAGE AND SITE LIGHTING-BID# 2014/15-3230-00-024** is hereby amended as noted in this **Addendum No. 1**.

This **Addendum No. 1** consists of **2** Typed Pages, **2** Sketches, **1** Attachment, **0** Specifications and **1** Drawing. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: February 10, 2015  
Angel Ayala – Purchasing Director

**ACKNOWLEDGEMENT**

Receipt of this **Addendum No. 1** shall be acknowledged in the space provided on the **ADDENDUM RECEIPT FORM (ARF)** (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah @ (305) 883-5871 and submitted with sealed bids.

**SKETCHES:**

SK-1 DUMPSTER WALL SECTION AND ENCLOSURE PLAN  
SK-2 TREATMENT COMPOUND-PLAN

**DRAWINGS:**

AS 4.3-DUMPSTER SECTIONS AND ELEVATIONS

**CLARIFICATIONS:**

1. THE STRUCTURE FOR THE DUMPSTER ENCLOSURE AND TREATMENT COMPOUND SHALL BE INCLUDED AS PART OF THIS BID. CONTRACTOR IS ALSO TO INCLUDE THE STUCCO FINISH TO ALL EXTERIOR WALLS. THE GATES WILL BE PROVIDED AND INSTALLED BY THE CITY. PLEASE REFER TO DRAWINGS/SKETCHES FOR ADDITIONAL INFORMATION.

2. USE "DUMPSTER WALL SECTION" FOR THE TREATMENT COMPOUND WALLS. BOTH AREAS ARE TO HAVE A 6" SLAB WITH 6 X 6-W1.4 X W1.4 WWF.
3. THE CITY WILL COVER THE MASTER BUILDING PERMIT ONLY.

**ATTACHEMENT:**

1. COPY OF PRE-BID MEETING SIGN IN SHEET.

**QUESTIONS:**

Question: What is the estimated value of the Public works complex parking lot paving, drainage and site lighting contract?

Answer: The estimated budget for this project is \$500,000.00

**ADDENDUM RECEIPT FORM**

**CITY OF HIALEAH  
PUBLIC WORKS COMPLEX  
3700 W 4 AVE  
HIALEAH, FLORIDA**

**CONTRACTOR'S NAME** \_\_\_\_\_

**ADDRESS** \_\_\_\_\_

**PHONE NO.** \_\_\_\_\_ **FAX NO.** \_\_\_\_\_


**CONTACT NAME** \_\_\_\_\_ **E-MAIL** \_\_\_\_\_

**THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY of HIALEAH @ (305) 687-2642**

<u><b>ADDENDUM</b></u>	<u><b>SIGNATURE</b></u>	<u><b>DATE</b></u>
1	_____	_____
_____	_____	_____
_____	_____	_____

**PUBLIC WORKS COMPLEX-PARKING LOT  
PAVING, DRAINAGE AND SITE LIGHTING  
BID #:2014/2015-3230-000-024**


**ARF**



1

DUMPSTER WALL SECTION

3/4"=1'-0"



C

DUMPSTER ENCLOSURE PLAN


SCALE 1/4" = 1'-0"




SK-1

SK-2

# PHASE 4

LAY  
DOWN YARD





### AS4.3

**PUBLIC WORKS PARKING LOT-PAVING, DRAINAGE AND SITE LIGHTING**

**LOCATION: PUBLIC WORKS COMPLEX**

[illegible]